



Town of Brunswick, Maine

Incorporated 1739
Brunswick Fire Department

"Working Today for a Safer Tomorrow"



KEN BRILLANT, CHIEF
JAMES MILLSON, DEPUTY CHIEF
JOSH SHEAN, DEPUTY CHIEF

119 PLEASANT STREET
BRUNSWICK, ME 04011
TELEPHONE 207-725-5541
FAX # 207-725-6638
WWW.BRUNSWICKME.ORG

September 30, 2024

Kristine Logan
Midcoast Regional Redevelopment Authority
15 Terminal Road
Brunswick, ME 04011

RE: Plan of corrective action receive

The email from Eric Perkins received on September 24, 2024, and the letter from Kristine Logan dated September 30, 2024, satisfy the requirements for the submittal of a plan of corrective action. You have met the obligations of the notice of violation. The updated inspection reports for Hangars 5 & 6 are required to be submitted for review upon completion of the maintenance and inspections.

We also discussed the considerations for removing the supplemental underwing protection systems. The requirements for hangars to be equipped with underwing protection is dependent on the wing area of the aircraft stored in the hangar. The current use of Hangar 5 does not require a supplemental suppression system. The current foam system is required until alternative suppression or modified hangar operations are approved. I have sent a separate letter regarding Hangar 5's Supplemental Protection System, stating that the supplemental suppression system is not required and the steps required if you choose to remove it.

Contact the Brunswick Fire Department, Fire Prevention Division for any questions or clarification.



Joshua Shean
Deputy Chief, Fire Prevention Division

CC: Julia Henze, Brunswick Town Manager