

Fire Alarm Inspection and Testing Report



Location Code: EWNXDIN

Contact: Owner or Manager

Contact Address: 2 PEGASUS STREET
Brunswick, ME 04011

Phone:

Email:

Property Evaluated: MRRA - HANGAR 6 (Assembly)
2 PEGASUS STREET
Brunswick, ME 04011

Description: Fire Alarm and Devices (FIRE ALARM
SYSTEM)

Work Order: SV2307030241/1

Company: Eastern Fire

Address: 170 Kittyhawk Ave., P.O. Box 1390
Auburn, ME 04210

Company Phone: 207-784-1507

Company Fax: 207-782-0566

Inspector: Alex Haggan
Not Required

Date of Work: 7/11/2023

Frequency: Annual

Tag: N/A

Deficiency Summary

Status: Open

Notification Appliances

Horn/Strobe(s) - # Installed: 60, # Tested: 60

HANGAR B EAST CORNER

HANGAR B WEST CORNER

HANGAR A BY DOOR A135

General Comments

These items are outside the regular scope of the required inspection and are not the result of an engineering review. This information is not intended to be all-inclusive but rather a list of items discovered as a by-product of the required inspection.

There are no general comments for this submission



Eastern Fire
170 Kittyhawk Ave., P.O. Box 1390
Auburn, ME 04210
Phone: 207-784-1507

Fire Alarm Inspection and Testing Report

1. Property Information

Tag _____ N/A
Inspection Frequency: _____ Annual
Property Being Evaluated: _____
MRRA - HANGAR 6 (Assembly) _____
Owner: _____
Owner or Manager _____
Owner's Phone Number: _____
Property Address: _____
2 PEGASUS STREET, Brunswick, ME, 04011 _____
Assembly Description: _____
Fire Alarm and Devices (FIRE ALARM SYSTEM) _____

2. Owner's Section

Has the Owners section been answered on another inspection report that will be submitted with this inspection report? ☐ Yes ☐ No ☒ N/A

3. Monitoring Information

Is there a monitoring entity? ☒ Yes ☐ No
Monitoring organization: _____ Centralarm
Phone: _____ 800-639-2066
Email: _____ N/A
Account number: _____ 196A5020
Phone line 1: _____ N/A
Phone line 2: _____ N/A
Means of transmission: _____ Radio
Entity to which alarms are retransmitted: _____ Brunswick FD
Phone: _____ 207-725-5521

4. Notifications Made Prior To Testing

	Contact	Time
Monitoring organization:	Centralarm	8:00 AM
Building management:	MRRA	8:00 AM

5. System Information - Panels / Power

5.1 Addressable Panels

Control Unit	Manufacturer: EST		Model Number: EST3		Location: NODE 2 - SPRINKLER ROOM		Software Revision: N/A	
SLC Loops	Max #: 1	# Utilized: 1	Addresses Available: N/A		NAC Circuits	Max #: 0	# Utilized: 0	Style/Class: N/A
Primary Power	Voltage: 120 VAC	Amps: 4 A	Overcurrent Protection Type: CIRCUIT BREAKER		Amps: N/A	Disconnecting Means Location: N/A		
Battery 1	Voltage: 12 VDC	Amps: 38 AH	Mfr Year: 2019	Load Test Battery 1	VDC: 13.21 VDC	Ah: 100%	Charger Voltage: 27.93 VDC	Result of Battery 1 & 2
Battery 2	Voltage: 12 VDC	Amps: 38 AH	Mfr Year: 2019	Load Test Battery 2	VDC: 13.19 VDC	Ah: 100%	Charger Voltage: 27.93 VDC	☒ Pass ☐ Fail ☐ Replaced
Secondary Power	Other Power Present? ☒ Yes ☐ No		Description: Generator					

Control Unit	Manufacturer: EDWARDS		Model Number: EST3		Location: NODE 1 - Electric Room B162		Software Revision: N/A	
SLC Loops	Max #: 1	# Utilized: 1	Addresses Available: N/A		NAC Circuits	Max #: 0	# Utilized: 0	Style/Class: N/A
Primary Power	Voltage: 120 VAC	Amps: 3.0 A	Overcurrent Protection Type: Circuit Breaker		Amps: 20 A	Disconnecting Means Location: ELB / CKT 17		
Battery 1	Voltage: 12 VDC	Amps: 35 AH	Mfr Year: 2019	Load Test Battery 1	VDC: 12.83 VDC	Ah: 90%	Charger Voltage: 26.93 VDC	Result of Battery 1 & 2
Battery 2	Voltage: 12 VDC	Amps: 35 AH	Mfr Year: 2019	Load Test Battery 2	VDC: 12.74 VDC	Ah: 80%	Charger Voltage: 26.93 VDC	☒ Pass ☐ Fail ☐ Replaced
Secondary Power	Other Power Present? ☒ Yes ☐ No		Description: Generator					

Control Unit	Manufacturer: EDWARDS		Model Number: EST3		Location: NODE 3 - Electric Room B173		Software Revision: N/A	
SLC Loops	Max #: 1	# Utilized: 1	Addresses Available: N/A		NAC Circuits	Max #: 0	# Utilized: 0	Style/Class: N/A
Primary Power	Voltage: 12 VAC	Amps: 3 A	Overcurrent Protection Type: Circuit Breaker		Amps: 20 A	Disconnecting Means Location: ELAB / CKT 52		
Battery 1	Voltage: 12 VDC	Amps: 35 AH	Mfr Year: 2019	Load Test Battery 1	VDC: 12.97 VDC	Ah: 90%	Charger Voltage: 26.93 VDC	Result of Battery 1 & 2
Battery 2	Voltage: 12 VDC	Amps: 35 AH	Mfr Year: 2019	Load Test Battery 2	VDC: 12.98 VDC	Ah: 100%	Charger Voltage: 26.93 VDC	☒ Pass ☐ Fail ☐ Replaced
Secondary Power	Other Power Present? ☒ Yes ☐ No		Description: Generator					

Control Unit	Manufacturer: EDWARDS		Model Number: EST3		Location: NODE 4 - Electrical Room A167		Software Revision: N/A	
SLC Loops	Max #: 1	# Utilized: 1	Addresses Available: N/A		NAC Circuits	Max #: 0	# Utilized: 0	Style/Class: N/A
Primary Power	Voltage: 120 VAC	Amps: 3 A	Overcurrent Protection Type: Circuit Breaker		Amps: 20 A	Disconnecting Means Location: ELA1 / CKT 44		

5.1 Addressable Panels								
Battery 1	Voltage: 12 VDC	Amps: 35 AH	Mfr Year: 2019	Load Test Battery 1	VDC: 13.18 VDC	Ah: 100%	Charger Voltage: 26.92 VDC	Result of Battery 1 & 2
Battery 2	Voltage: 12 VDC	Amps: 35 AH	Mfr Year: 2019	Load Test Battery 2	VDC: 13.23 VDC	Ah: 100%	Charger Voltage: 26.92 VDC	☒ Pass ☐ Fail ☐ Replaced
Secondary Power	Other Power Present? ☒ Yes ☐ No		Description: Generator					

5.3 Additional Power Supplies

Are there additional power supplies?

☒ Yes ☐ No

Power Supplies								
Control Unit	Manufacturer: EST		Model Number: 31053		Location: Inside NODE 2		Disconnecting Location: N/A	
Battery 1	Voltage: 12 VDC	Amps: 7 AH	Mfr Year: 2019	Load Test Battery 1	VDC: 12.96 VDC	Ah: 100%	Charger Voltage: 27.17 VDC	Result of Battery 1 & 2
Battery 2	Voltage: 12 VDC	Amps: 7 AH	Mfr Year: 2019	Load Test Battery 2	VDC: 12.70 VDC	Ah: 80%	Charger Voltage: 27.17 VDC	☒ Pass ☐ Fail ☐ Replaced

Control Unit	Manufacturer: AES INTELLINET		Model Number: 7788F		Location: SPRINKLER ROOM NEXT TO NODE 2		Disconnecting Location: N/A	
Battery 1	Voltage: 12 VDC	Amps: 7 Ah	Mfr Year: 2019	Load Test Battery 1	VDC: 13.02 VDC	Ah: 100%	Charger Voltage: 13.84 VDC	Result of Battery 1 & 2
Battery 2	Voltage: N/A	Amps: N/A	Mfr Year: N/A	Load Test Battery 2	VDC: N/A	Ah: N/A	Charger Voltage: N/A	☒ Pass ☐ Fail ☐ Replaced

Control Unit	Manufacturer: EDWARDS		Model Number: 31053		Location: INSIDE NODE 1		Disconnecting Location: N/A	
Battery 1	Voltage: 12 VDC	Amps: 7 Ah	Mfr Year: 2019	Load Test Battery 1	VDC: 12.98 VDC	Ah: 100%	Charger Voltage: 27.50 VDC	Result of Battery 1 & 2
Battery 2	Voltage: 12 VDC	Amps: 7 Ah	Mfr Year: 2019	Load Test Battery 2	VDC: 13.06 VDC	Ah: 100%	Charger Voltage: 27.50 VDC	☒ Pass ☐ Fail ☐ Replaced

Control Unit	Manufacturer: EDWARDS		Model Number: 31053		Location: INSIDE NODE 3		Disconnecting Location: N/A	
Battery 1	Voltage: 12 VDC	Amps: 12 Ah	Mfr Year: 2019	Load Test Battery 1	VDC: 13.07 VDC	Ah: 100%	Charger Voltage: 27.05 VDC	Result of Battery 1 & 2
Battery 2	Voltage: 12 VDC	Amps: 12 Ah	Mfr Year: 2019	Load Test Battery 2	VDC: 13.16 VDC	Ah: 100%	Charger Voltage: 27.05 VDC	☒ Pass ☐ Fail ☐ Replaced

Control Unit	Manufacturer: EDWARDS		Model Number: 31053		Location: INSIDE NODE 4		Disconnecting Location: N/A	
Battery 1	Voltage: 12 VDC	Amps: 12 Ah	Mfr Year: 2019	Load Test Battery 1	VDC: 13.09 VDC	Ah: 100%	Charger Voltage: 27.16 VDC	Result of Battery 1 & 2
Battery 2	Voltage: 12 VDC	Amps: 12 Ah	Mfr Year: 2019	Load Test Battery 2	VDC: 13.15 VDC	Ah: 100%	Charger Voltage: 27.16 VDC	☒ Pass ☐ Fail ☐ Replaced

6. Testing Results

6.1 Control Unit and Related Equipment

Description	Visual Inspection	Functional Test	Results
Control unit	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A
Lamps / LEDs / LCDs	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A
Fuses	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A
Trouble signals	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A
Disconnect switches	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A
Ground-fault monitoring	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A
Supervision	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A
Annunciators	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A
Remote power panels	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A
Other	☐ Yes ☐ No	☐ Yes ☐ No	☐ Pass ☐ Fail ☐ N/A

6.2 Secondary Power

Description	Visual Inspection	Functional Test	Results
Battery condition	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A
Load voltage	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A
Discharge test	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A
Charger test	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A
Remote panel batteries	☒ Yes ☐ No	☒ Yes ☐ No	☒ Pass ☐ Fail ☐ N/A

6.3 Notification Appliances

Include Notification Appliances Table on this Report?

☒ Yes ☐ No

Notification Appliances

Appliance Type	# Installed	# Tested	Test Results
Bell(s)	0	0	☐ Pass ☐ Fail ☒ N/A
Horn(s)	0	0	☐ Pass ☐ Fail ☒ N/A
Horn/Strobe(s)	60	60	☐ Pass ☒ Fail ☐ N/A
Mini Horn(s)	0	0	☐ Pass ☐ Fail ☒ N/A
Speaker(s)	0	0	☐ Pass ☐ Fail ☒ N/A
Speaker/Strobe(s)	0	0	☐ Pass ☐ Fail ☒ N/A
Strobe(s)	20	20	☒ Pass ☐ Fail ☐ N/A

6.4 Interface Equipment

Complete supplementary interface component test form for all interface components.

Circuit Interface / Signaling Line Circuit Interface / Fire Alarm Control Interface

6.5 Supervising Station Monitoring

Description	Yes/No	Time (sec)	Results
Alarm signal	☐ Yes ☐ No		☐ Pass ☐ Fail ☒ N/A
Alarm restoration	☐ Yes ☐ No		☐ Pass ☐ Fail ☒ N/A
Trouble signal	☐ Yes ☐ No		☐ Pass ☐ Fail ☒ N/A
Trouble restoration	☐ Yes ☐ No		☐ Pass ☐ Fail ☒ N/A
Supervisory signal	☐ Yes ☐ No		☐ Pass ☐ Fail ☒ N/A
Supervisory restoration	☐ Yes ☐ No		☐ Pass ☐ Fail ☒ N/A

6.6 Air Sampling Detection

Is there Air Sampling Detection?

☐ Yes ☒ No

6.7 Devices

Legend

AED - Automated External Defibrillator	AF - Anti-Freeze	AO - Audio Only
APS - Air Pressure Switch	AS - Abort Station	AV - Audio/Video
BATT - Batteries	BP - Backflow Prevention	CM - Control Module
COM - Communicator	CON - Controller	CoD - Carbon Monoxide Detector
Combo Detector - Combo Detector	DA - Damper	DD - Duct Detector
DH - Door Holder	DSD - Door Smoke Detector	ED - Electrical Driver
EL - Emergency/Exit Light	ER - Elevator Recall	FACP - Fire Alarm Control Panel
FDC - Fire Department Connection	FP - Fire Pump	FP-D (NOFLOW) - Fire Pump Diesel No Flow
FP-E (NOFLOW) - Fire Pump Electric No Flow	FPP - Fire Pump Power	FPR - Fire Pump Running
GAUGE - GAUGE	H/S - Horn-Strobes	HD - Heat Detector
HOOD - HOOD	HORN - Horns	INSPT - Inspector's Test
JC - Jockey Controller	JP - Jockey Pump	LA - Low Air
LS-HIGH - Level Switch High	LS-LOW - Level Switch Low	MM - Monitor Module (Ansul, temp, CO, etc)
MON - Monitoring	MR - Manual Release	Other - Other
PR - Phase Reversal	PS - Pull Station	PWS - Power Supply
RDD - Roll Down Door	Relay Module - Relay Module	S/S - Speaker Strobes
SBS - Sprinkler Box Spares	SC - Signal/Sounder Control	SD - Smoke Detector
SD-Ion - Ion Smoke Detector	SD-Photo - Photo Smoke Detector	SPKLR HEADS - SPKLR HEADS
SPKR - Speakers	STANDPIPE - STANDPIPE	STROBE - Strobes
TEMP - Temperature Switch	TS - Tamper Switch	VO - Visual Only
WF - Waterflow		

Asset Type	Total	Tested	Not Tested	Passed	Failed
AS	2	0	2	0	0
DH	2	0	2	0	0
FPP	2	0	2	0	0
HD	39	0	39	0	0
MM	3	0	3	0	0
PR	2	0	2	0	0
RDD	3	0	3	0	0
RELEASE	8	0	8	0	0
TS	19	0	19	0	0

Asset Type	Total	Tested	Not Tested	Passed	Failed
DD	17	0	17	0	0
ER	1	0	1	0	0
FPR	3	0	3	0	0
LA	4	0	4	0	0
MR	2	0	2	0	0
PS	30	28	2	28	0
Relay Module	11	0	11	0	0
SD	21	15	6	15	0
WF	18	0	18	0	0

Zone: XPNDR 1

Zone: XPNDR 1							
Asset Type	Address	Location	Notes	Frequency	Last Tested	Test Results	Comments
MM	P1D135	AFFF #6 TROUBLE/SUPERVISORY				N/A	
SD	P1D007	BUNKROOM C114	COULD NOT LOCATE			N/A	
SD	P1D006	BUNKROOM D109		Annual	7/12/2023	Pass	

Zone: XPNDR 1

Asset Type	Address	Location	Notes	Frequency	Last Tested	Test Results	Comments
● SD	P1D004	COMM ROOM C124		Annual	7/12/2023	Pass	
■ PS	P1D126	CORRIDOR C125		Annual	7/11/2023	Pass	
● SD	P1D003	ELECTRIC ROOM C123		Annual	7/12/2023	Pass	
■ PS	P1D128	HALLWAY D104		Annual	7/11/2023	Pass	
■ PS	P1D132	HANGAR C NORTH CENTER		Annual	7/11/2023	Pass	
■ PS	P1D130	LINE SHACK D110		Annual	7/11/2023	Pass	
● DD	P1D005	ROOM D107 / AHU 5 RETURN				N/A	
● DD	P1D001	ROOM D112 / AHU 5 SUPPLY				N/A	
● DD	P1D002	ROOM D112 / AHU 5 SUPPLY				N/A	
■ PS	P1D131	SOUTHWEST CORNER HANGAR C		Annual	7/11/2023	Pass	
■ PS	P1D129	STORAGE D111		Annual	7/11/2023	Pass	
■ PS	P1D127	VESTIBULE C115		Annual	7/11/2023	Pass	

Zone: XPNDR 2

Zone: XPNDR 2							
Asset Type	Address	Location	Notes	Frequency	Last Tested	Test Results	Comments
↗ Relay Module	P2D191	1ST FLOOR DUCT SMOKE ZONE 11	RELAY TO AES			N/A	
★ LA	P2D167	1ST FLOOR EAST				N/A	
☒ WF	P2D170	1ST FLOOR EAST				N/A	
☒ WF	P2D182	1ST FLOOR EAST ZONE 2				N/A	
↗ Relay Module	P2D189	1ST FLOOR SMOKE ZONE 9	RELAY TO AES			N/A	
★ LA	P2D168	1ST FLOOR WEST				N/A	
☒ WF	P2D172	1ST FLOOR WEST				N/A	
☒ WF	P2D181	1ST FLOOR WEST ZONE 1				N/A	
↗ Relay Module	P2D193	1ST FLOOR ZONE 13	RELAY TO AES			N/A	
↗ Relay Module	P2D190	2ND FLOOR SMOKE/DUCTS/PULLS ZONE 10	RELAY TO AES			N/A	
☒ WF	P2D183	2ND FLOOR ZONE 3				N/A	
⊕ AS	P2D239	ABORT				N/A	
⊕ AS	P2D245	ABORT				N/A	
☒ WF	P2D187	AFFF EAST HANGAR ZONE 7				N/A	
☒ WF	P2D186	AFFF WEST HANGAR BAY ZONE 6				N/A	
● SD	P2D007	BUNKROOM B151		Annual	7/11/2023	Pass	
● SD	P2D001	COMM ROOM B159		Annual	7/12/2023	Pass	
● SD	P2D003	COMM ROOM B163		Annual	7/12/2023	Pass	
☒ DH	P2D176	DOOR HOLDERS				N/A	

Zone: XPNDR 2							
Asset Type	Address	Location	Notes	Frequency	Last Tested	Test Results	Comments
WF	P2D166	EAST ROOF B169				N/A	
TS	P2D153	EAST ROOF WATER ROOM B169				N/A	
SD	P2D004	ELECTRIC ROOM B162		Annual	7/11/2023	Pass	
WF	P2D185	ELEVATOR ZONE 5				N/A	
RDD	P2D209	FIRE SHUTTERS				N/A	
TS	P2D165	FOAM PUMOS VALVE 7				N/A	
PR	P2D203	FOAM PUMP 1 PHASE REVERSAL				N/A	
FPP	P2D201	FOAM PUMP 1 POWER LOSS				N/A	
FPR	P2D202	FOAM PUMP 1 RUNNING				N/A	
Relay Module	P2D207	FOAM PUMP 1 START				N/A	
PR	P2D206	FOAM PUMP 2 PHASE REVERSAL				N/A	
FPP	P2D204	FOAM PUMP 2 POWER LOSS				N/A	
FPR	P2D205	FOAM PUMP 2 RUNNING				N/A	
Relay Module	P2D208	FOAM PUMP 2 START				N/A	
FPR	P2D196	FOAM PUMP FLOW AND RUNNING ZONE 16				N/A	
TS	P2D160	FOAM PUMPS VALVE 2				N/A	
TS	P2D162	FOAM PUMPS VALVE 4				N/A	
TS	P2D163	FOAM PUMPS VALVE 5				N/A	
TS	P2D164	FOAM PUMPS VALVE 6				N/A	
LA	P2D175	HANGAR A PRE-ACTION				N/A	
HD	P2D126	HANGAR B/C B188				N/A	
HD	P2D127	HANGAR B/C B188				N/A	
HD	P2D130	HANGAR B/C B188				N/A	
HD	P2D133	HANGAR B/C B188				N/A	
HD	P2D139	HANGAR B/C B188				N/A	
HD	P2D142	HANGAR B/C B188				N/A	
HD	P2D126	HANGAR B/C B189				N/A	
HD	P2D131	HANGAR B/C B189				N/A	
HD	P2D132	HANGAR B/C B189				N/A	
HD	P2D137	HANGAR B/C B189				N/A	
HD	P2D138	HANGAR B/C B189				N/A	
HD	P2D143	HANGAR B/C B189				N/A	
HD	P2D128	HANGAR B/C C119				N/A	
HD	P2D129	HANGAR B/C C119				N/A	
HD	P2D134	HANGAR B/C C119				N/A	
HD	P2D135	HANGAR B/C C119				N/A	



Eastern Fire
 170 Kittyhawk Ave., P.O. Box 1390
 Auburn, ME 04210
 Phone: 207-784-1507

Zone: XPNDR 2							
Asset Type	Address	Location	Notes	Frequency	Last Tested	Test Results	Comments
HD	P2D140	HANGAR B/C C119				N/A	
HD	P2D141	HANGAR B/C C119				N/A	
PS	P2D145	HANGAR B/C DOOR MULLION B118		Annual	7/11/2023	Pass	
PS	P2D144	HANGAR B/C DOOR MULLION C119		Annual	7/11/2023	Pass	
LA	P2D174	HANGAR B/C PRE-ACTION				N/A	
MM	P2D177	HANGAR B AFFF #5				N/A	
PS	P2D146	HANGAR B NORTH CENTER		Annual	7/11/2023	Pass	
PS	P2D147	HANGAR B NORTHEAST CORNER		Annual	7/11/2023	Pass	
WF	P2D171	MAIN RISER EAST				N/A	
MR	P2D240	MANUAL RELEASE				N/A	
MR	P2D246	MANUAL RELEASE				N/A	
WF	P2D184	MEZZANINE ZONE 4				N/A	
Relay Module	P2D192	MEZZANINE ZONE 12	RELAY TO AES			N/A	
TS	P2D150	PAINT BOOTH AREA B143				N/A	
RELEASE	P2D243	PRE-RELEASE 1				N/A	
RELEASE	P2D249	PRE-RELEASE 1				N/A	
RELEASE	P2D244	PRE-RELEASE 2				N/A	
RELEASE	P2D250	PRE-RELEASE 2				N/A	
RELEASE	P2D241	RELEASE 1				N/A	
RELEASE	P2D247	RELEASE 1				N/A	
RELEASE	P2D242	RELEASE 2				N/A	
RELEASE	P2D248	RELEASE 2				N/A	
Relay Module	P2D195	ROOF DECK PRE-ACTION EAST ZONE 15	NOT IN USE RELAY TO AES			N/A	
Relay Module	P2D194	ROOF DECK PRE-ACTION WEST ZONE 14	NOT IN USE RELAY TO AES			N/A	
DD	P2D006	ROOM B115 / AHU 4 SUPPLY				N/A	
DD	P2D002	ROOM B122 / AHU				N/A	

Zone: XPNDR 2							
Asset Type	Address	Location	Notes	Frequency	Last Tested	Test Results	Comments
		3 SUPPLY					
DD	P2D005	ROOM B163 / AHU 4 RETURN				N/A	
TS	P2D154	ROOM B169 FIRST FLOOR EAST				N/A	
TS	P2D159	ROOM B169 FOAM PUMPS VALVE 1				N/A	
TS	P2D161	ROOM B169 FOAM PUMPS VALVE 3				N/A	
TS	P2D152	ROOM B169 MAIN CONTROL				N/A	
TS	P2D155	ROOM B169 MAIN RISER EAST				N/A	
TS	P2D158	ROOM B169 WET RISER TO FOAM SYSTEM				N/A	
TS	P2D156	ROOM B169 1ST FLOOR WEST				N/A	
PS	P2D148	VESTIBULE B155		Annual	7/11/2023	Pass	
WF	P2D169	WEST ROOF				N/A	
WF	P2D157	WEST ROOF WATER ROOM B169				N/A	
WF	P2D173	WET RISER TO FOAM SYSTEM				N/A	
Relay Module	P2D188	ZONE 8	RELAY TO AES			N/A	

Zone: XPNDR 3

Zone: XPNDR 3							
Asset Type	Address	Location	Notes	Frequency	Last Tested	Test Results	Comments
SD	P3D016	1ST FLOOR ELEVATOR LOBBY				N/A	
WF	P3D141	2ND FLOOR				N/A	
SD	P3D003	2ND FLOOR COMM ROOM A270		Annual	7/12/2023	Pass	
SD	P3D005	2ND FLOOR ELECTRIC ROOM A261		Annual	7/12/2023	Pass	
SD	P3D022	2ND FLOOR ELEVATOR LOBBY				N/A	
PS	P3D135	2ND FLOOR ELEVATOR LOBBY B278		Annual	7/11/2023	Pass	
PS	P3D134	2ND FLOOR HALLWAY A274		Annual	7/11/2023	Pass	
PS	P3D133	2ND FLOOR HALLWAY B280		Annual	7/11/2023	Pass	
DD	P3D004	2ND FLOOR ROOM A263 / AHU 6 SUPPLY				N/A	
TS	P3D138	2ND FLOOR STAIR 3 B268				N/A	
Relay Module	P3D160	ACCESS CONTROL 2ND FLOOR COMMON ROOM A270				N/A	

Zone: XPNDR 3							
Asset Type	Address	Location	Notes	Frequency	Last Tested	Test Results	Comments
● SD	P3D021	BUNKROOM A126		Annual	7/12/2023	Pass	
⬮ TS	P3D159	BY ELEVATOR				N/A	
⚡ WF	P3D158	BY ELEVATOR				N/A	
● SD	P3D002	ELECTRIC ROOM B173		Annual	7/11/2023	Pass	
⬮ TS	P3D137	ELEVATOR LOBBY B161				N/A	
⚙ HD	P3D017	ELEVATOR MACHINE ROOM B160				N/A	
● SD	P3D019	ELEVATOR MACHINE ROOM B160				N/A	
⚡ WF	P3D140	ELEVATOR MACHINE ROOM B160				N/A	
● SD	P3D015	ELEVATOR SHAFT				N/A	
■ ER	P3D152	FIRE HAT				N/A	
■ RDD	P3D157	FIRE SHUTTER A141				N/A	
⚙ HD	P3D148	GENERATOR ROOM B170				N/A	
⬮ DH	P3D150	HALLWAY B179				N/A	
■ PS	P3D131	HALLWAY B179		Annual	7/11/2023	Pass	
⚡ MM	P3D151	HANAGR A AFFF #3				N/A	
■ PS	P3D128	HANGAR A NORTHWEST CORNER		Annual	7/11/2023	Pass	
■ PS	P3D126	HANGAR A SOUTHWEST CORNER		Annual	7/11/2023	Pass	
■ PS	P3D127	HANGAR B/C SOUTHEAST CORNER		Annual	7/11/2023	Pass	
● SD	P3D014	MAIN ELECTRIC ROOM B171		Annual	7/12/2023	Pass	
■ PS	P3D136	MEZZANINE		Annual	7/11/2023	Pass	
⚡ WF	P3D142	MEZZANINE				N/A	
⬮ DD	P3D008	MEZZANINE MAU1 OUTSIDE AIR				N/A	
⬮ DD	P3D009	MEZZANINE MAU1 SUPPLY				N/A	
⬮ DD	P3D012	MEZZANINE MAU2 OUTSIDE AIR				N/A	
⬮ DD	P3D013	MEZZANINE MAU2 SUPPLY				N/A	
⬮ DD	P3D006	MEZZANINE MAU 3 OUTSIDE AIR				N/A	
⬮ DD	P3D007	MEZZANINE MAU 3 SUPPLY				N/A	
⬮ DD	P3D010	MEZZANINE MAU4 OUTSIDE AIR				N/A	
⬮ DD	P3D011	MEZZANINE MAU4 SUPPLY				N/A	
⬮ TS	P3D139	MEZZANINE STAIR 3				N/A	

Zone: XPNDR 3

Asset Type	Address	Location	Notes	Frequency	Last Tested	Test Results	Comments
● SD	P3D001	ROOM B169 ABOVE FACP		Annual	7/12/2023	Pass	
■ PS	P3D130	STAIR 3 B168		Annual	7/11/2023	Pass	
⚙ HD	P3D023	TOP OF ELEVATOR SHAFT				N/A	
■ PS	P3D132	VESTIBULE A156		Annual	7/11/2023	Pass	
■ PS	P3D129	VESTIBULE A184	COULD NOT LOCATE			N/A	

Zone: XPNDR 4

Zone: XPNDR 4							
Asset Type	Address	Location	Notes	Frequency	Last Tested	Test Results	Comments
ⓘ DD	P4D001	AHU 1 SUPPLY / ROOM A112				N/A	
ⓘ DD	P4D002	AHU 2 SUPPLY / ROOM A130				N/A	
● SD	P4D004	COMM ROOM A166		Annual	7/12/2023	Pass	
● SD	P4D003	ELECTRICAL ROOM A167		Annual	7/11/2023	Pass	
■ RDD	P4D158	FIRE SHUTTER TRON SUPPLY A151				N/A	
● SD	P4D005	GROUND FLOOR BY COMM ROOM A166	COULD NOT LOCATE			N/A	
■ PS	P4D157	HALLWAY A125	COULD NOT LOCATE			N/A	
⚙ HD	P4D138	HANGAR A A177				N/A	
⚙ HD	P4D128	HANGAR A A175				N/A	
⚙ HD	P4D129	HANGAR A A175				N/A	
⚙ HD	P4D134	HANGAR A A175				N/A	
⚙ HD	P4D135	HANGAR A A175				N/A	
⚙ HD	P4D140	HANGAR A A175				N/A	
⚙ HD	P4D141	HANGAR A A175				N/A	
⚙ HD	P4D127	HANGAR A A176				N/A	
⚙ HD	P4D130	HANGAR A A176				N/A	
⚙ HD	P4D133	HANGAR A A176				N/A	
⚙ HD	P4D136	HANGAR A A176				N/A	
⚙ HD	P4D139	HANGAR A A176				N/A	
⚙ HD	P4D142	HANGAR A A176				N/A	
⚙ HD	P4D126	HANGAR A A177				N/A	
⚙ HD	P4D131	HANGAR A A177				N/A	
⚙ HD	P4D132	HANGAR A A177				N/A	
⚙ HD	P4D137	HANGAR A A177				N/A	
⚙ HD	P4D143	HANGAR A A177				N/A	
■ PS	P4D144	HANGAR A DOOR MULLION A175		Annual	7/11/2023	Pass	
■ PS	P4D145	HANGAR A DOOR MULLION A176		Annual	7/11/2023	Pass	
■ PS	P4D146	HANGAR A NORTH CENTER		Annual	7/11/2023	Pass	
■ PS	P4D147	HANGAR A NORTHEAST CORNER		Annual	7/11/2023	Pass	



Eastern Fire
170 Kittyhawk Ave., P.O. Box 1390
Auburn, ME 04210
Phone: 207-784-1507

Zone: XPNDR 4

Asset Type	Address	Location	Notes	Frequency	Last Tested	Test Results	Comments
PS	P4D148	HANGAR A SOUTHEAST CORNER		Annual	7/11/2023	Pass	
TS	P4D152	PAINT BOOTH AREA A147				N/A	
PS	P4D149	TRON SUPPLY ROOM A151		Annual	7/11/2023	Pass	

7. Notifications That Testing Is Complete

	Contact	Time
Monitoring organization:	Centralarm	10:30 AM
Building management:	MRRA	10:30 AM

8. System Restored To Normal Operation

Date: 7/11/2023
Time: 10:30 AM

9. Observations

These items are outside the regular scope of the required inspection and are not the result of an engineering review. This information is not intended to be all-inclusive but rather a list of items discovered as a by-product of the required inspection.
Please see the summary section at the top of the form for the comments.

10. Inspector Information:

Test Verification:
Inspected By Alex Haggan
Inspector Signature 
Inspector License: Not Required
Date of Work 7/11/2023
Inspection Notes